

# Consumer Confidence Report

## Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to

## MINONK

### IL2030400

The source of drinking water used by

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Annual Water Quality Report for the period of January 1 to December 31, 2017

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name Tony Foster

Phone 309-432-2644

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

## Annual Drinking Water Quality Report

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

MINONK is Ground Water

### Source Water Information

Source Water Name	Report Status
Location	Type of Water
WELL 1 (31427) In Minonk city limits	active GW
WELL 2 (31428) In Minonk city limits	active GW
WELL 3 (00132) In Minonk city limits	active GW
WELL 4 (01499) NW CORNER OF CITY PARK NORTH WEST CORNER OF CITY PARK	active GW

### Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 309-432-2644 To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: MINONK To determine Minonk's susceptibility to contamination, a Well Site Survey, published in 1991 by the Illinois EPA, was reviewed. Based on the information contained in this document, three potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the Minonk community water supply wells. These include one grain elevator, one above ground petroleum storage, and one below ground petroleum storage. Information received from the city indicated that the below ground petroleum storage (map code 01207) has been removed and the grain elevator is no longer in existence. The information received from the City of Minonk also indicated that the following possible fuel tank contamination sources have been removed: IEMA #20001075 (Young Chevrolet Company), #891958 (City of Minonk), #892210 (D&D Scrap Tire), #903442 (Fieldcrest C.U.S.D. #6). The Illinois EPA has determined that Minonk wells #1, #2, and #3 are not susceptible to IOC, VOC, or SOC contamination. This determination is based on a number of criteria including: monitoring conducted at the well, monitoring conducted at the entry point to the distribution system, and the available hydrogeologic data for the well. In anticipation of the U.S. EPA's proposed Ground Water Rule, the Illinois EPA has determined that the City of Minonk water supply is not vulnerable to viral contamination. This determination is based upon the evaluation of the following criteria during the Vulnerability Waiver Process: the wells are properly constructed with sound integrity and proper site conditions, there is a hydrogeologic barrier that restricts pathogen movement, all potential routes and sanitary defects have been mitigated such that the source water is adequately protected, monitoring data did not indicate a history of disease outbreak, and the sanitary survey of the water supply did not indicate a viral contamination threat. However, having stated this, the U.S. EPA is proposing to require States to identify systems in karst, gravel, and fractured bedrock aquifer systems as sensitive. Water systems utilizing these aquifer types would be required to perform routine source water monitoring. Because the facility's wells are constructed in a confined aquifer, which should provide an adequate degree of protection to prevent the movement of pathogens into the wells, well hydraulics were not considered to be a significant factor in the vulnerability determination.

### Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

### Lead and Copper

Date Sampled
MCLG
Action Level (AL)
90th Percentile
# Sites Over AL
Units

Likely Source of Contamination  
**Copper**

Violation

06/21/2016  
1.3  
1.3  
0.53  
0  
ppm  
N

Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.  
**Lead**

06/21/2016  
0  
15  
2.4  
0  
ppb  
N

Corrosion of household plumbing systems; Erosion of natural deposits.

### **Water Quality Test Results**

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

### **Regulated Contaminants Detected**

**2017**

**Water Quality Test Results**

na:

not applicable.

mrem:

millirems per year (a measure of radiation absorbed by the body)

ppb:

micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm:

milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT:

A required process intended to reduce the level of a contaminant in drinking water.

**Regulated Contaminants**

**Disinfectants and Disinfection By-Products**

	Collection Date
	Highest Level Detected
	Range of Levels Detected
	MCLG
	MCL
	Units
	Violation

Likely Source of Contamination

**Chlorine**

12/31/2017  
0.5  
0.4 - 0.6  
MRDLG = 4  
MRDL = 4  
ppm  
N

Water additive used to control microbes.

**Total Trihalomethanes (THM)**

2017  
5  
5.17 - 5.17  
No goal for the total  
80  
ppb  
N

By-product of drinking water disinfection.

**Inorganic Contaminants**

	Collection Date
	Highest Level Detected
	Range of Levels Detected
	MCLG
	MCL
	Units
	Violation

Likely Source of Contamination

**Arsenic**

01/08/2015  
2.3  
2.3 - 2.3  
0  
10  
ppb  
N

Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.

**Barium**

01/08/2015  
0.0092  
0.0092 - 0.0092  
2  
2  
ppm  
N

Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.

**Fluoride**

01/08/2015  
0.962  
0.962 - 0.962  
4

4.0  
ppm  
N

Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

**Iron**

01/08/2015  
0.04  
0.04 - 0.04

1.0  
ppm  
N

This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.

**Manganese**

01/08/2015  
1.7  
1.7 - 1.7  
150  
150  
ppb  
N

This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.

**Sodium**

01/08/2015  
140  
140 - 140

ppm  
N

Erosion from naturally occurring deposits. Used in water softener regeneration.

**Radioactive Contaminants**

Collection Date  
Highest Level Detected  
Range of Levels Detected  
MCLG  
MCL  
Units  
Violation

Likely Source of Contamination  
**Combined Radium 226/228**

2017  
5  
4.89 - 4.89  
0  
5  
pCi/L

Erosion of natural deposits.  
**Gross alpha excluding radon and uranium**

N  
2017  
8  
8.21 - 8.21  
0  
15  
pCi/L  
N

Erosion of natural deposits.