

Consumer Confidence Report

Annual Drinking Water Quality Report

TEUTOPOLIS

IL0490450

Annual Water Quality Report for the period of January 1 to December 31, 2024

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by
TEUTOPOLIS is Purchased Surface Water

For more information regarding this report contact:

Name Carl Pals

Phone 217-857-3543

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier

to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact Carl Pals at 217-857-3543. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name		Type of Water	Report Status	Location
CC 03-MASTER METER	FF IL0490250 TP01	SW	emergency backup	AT BOOSTER STATION 1.5 W OF NEW ET
CC 04-MASTER METER	FFIL0790100	GW	<u>active</u>	20 miles south east at Newton ET
WELL 1 (47828)		GW	<u>active</u>	IN PLANT ON E SIDE OF TOWN
WELL 2 (47829)		GW	<u>active</u>	2 MI NE OF TOWN S OF RR
WELL 3 (47830)		GW	<u>active</u>	2 MI NE OF TOWN, E OF WELL2

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 217.657.3543. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: TEUTOPOLISTo determine Teutopolis' susceptibility to groundwater contamination, the Illinois Rural Water Association conducted a well site survey in May, 2002. Based on this information, there are 6 potential sources of groundwater contamination that could pose a hazard to groundwater utilized by Teutopolis' community water supply. These include 1 cleaning and electrical supplies manufacturing facility, 1 auto repair shop, 1 petroleum and natural gas pipeline, and 3 below ground fuel storage tanks. In addition, information provided by the Leaking Underground Storage Tank and Remedial Project Management Sections of the Illinois EPA indicated sites with on-going remediation that might be of concern. Based upon this information, the Illinois EPA has determined that the Teutopolis Community Water Supply's source water is susceptible to contamination. As such, the Illinois EPA has provided 5-year recharge area calculations for the wells. The land use within the recharge areas of the wells was analyzed as part of this susceptibility determination. This land use includes residential, commercial and agricultural properties. Source of Water: EFFINGHAM Illinois EPA considers all surface water sources of public water supply to be susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection. Primary sources of pollution in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion. Source of Water: TEUTOPOLISTo determine Teutopolis' susceptibility to groundwater contamination, the Illinois Rural Water Association conducted a well site survey in May, 2002. Based on this information, there are 6 potential sources of groundwater contamination that could pose a hazard to groundwater utilized by Teutopolis' community water supply. These include 1 cleaning and electrical supplies manufacturing facility, 1 auto repair shop, 1 petroleum and natural gas pipeline, and 3 below ground fuel storage tanks. In addition, information provided by the Leaking Underground Storage Tank and Remedial Project Management Sections of the Illinois EPA indicated sites with on-going remediation that might be of concern. Based upon this information, the Illinois EPA has determined that the Teutopolis Community Water Supply's source water is susceptible to contamination. As such, the Illinois EPA has provided 5-year recharge area calculations for the wells. The land use within the recharge areas of the wells was analyzed as part of this susceptibility determination. This land use includes residential, commercial and agricultural properties. Source of Water: NEWTON The Illinois EPA considers the source water of Newton's wells to be susceptible to IOC and SOC contamination, but does not consider the wells susceptible to VOC contamination. This determination was made primarily based on the identification of potential sources and routes of contamination, land-use activities around the wells, available hydrogeologic data, and monitoring results. Materials reviewed included the Well Site Survey Report, published in 1990, a Phase II Wellhead Protection Area (WHPA) Delineation, and additional field surveys. Other material reviewed includes the City of Newton's Source Water Protection Plan, published in 2013, in cooperation with the Illinois Rural Water Association. During the surveys of the source water protection area, no potential sources, routes, or possible problem sites were identified within 2,000 feet of the 400 foot minimum setback zones, the 1,000 foot Maximum Setback zones, or the Phase II WHPAs. Part of the land within the Phase II WHPA is utilized for agricultural purposes which increases the susceptibility to groundwater contamination of SOCs from pesticides and herbicides and IOCs such as nitrate used for fertilizing. Sampling performed to assess for pathogenic contamination (e.g., virus, total coliform, e-coli) has also demonstrated that the source water is not susceptible to these types of contaminants.

2024 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: 0.0685 ppm to 0.139 ppm

Lead Range: 0 to 0

To obtain a copy of the system's lead tap sampling data: call 217 857 3543

CIRCLE ONE: Our Community Water Supply has/has not developed a service line material inventory.

To obtain a copy of the system's service line inventory: call 217 857 3543

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1.3	1.3	0.377	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na:

not applicable.

Water Quality Test Results

mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	1	0.8 - 1.2	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2024	12	6 - 24.4	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	38	15.4 - 35.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2024	0.152	0.152 - 0.152	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2024	0.58	0.58 - 0.58	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Sodium	2024	61400	61400 - 61400			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	06/10/2020	0.8	0.8 - 0.8	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	04/26/2021	2	2 - 2	0	15	pCi/L	N	Erosion of natural deposits.

Newton

Source Water Information

Source Water Names		Type of Water	Report Status	Location
WELL 5 (00326)	SHALLOW IN EMBARRASS	GW	ACTIVE	Located 2141 feet Northwest of the intersection of N. 1030 th St. and IL 130
WELL 10 (02170)	IN EMBARRASS	GW	ACTIVE	Located 1008 feet north-northwest of the intersection of N. 1030 th St. and IL 130
WELL 7 (01058)	IN EMBARRASS	GW	ACTIVE	Located 1580 feet north-northwest of the intersection of N. 1030 th St. and IL 130
WELL 8 (01868)	IN EMBARRASS FLOOD	GW	ACTIVE	Located 1783 feet Northwest of the intersection of N. 1030 th St. and IL 130
WELL 9 (01869)	IN EMBARRASS	GW	ACTIVE	Located 1901 feet West of the intersection of N. 1030 th St. and IL 130

2024 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level Goal (ALG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

To obtain a copy of the system's lead tap sampling data, please call City Hall at 618-783-8451 or visit City Hall at 108 North Van Buren Street in Newton.

Our community Water Supply has developed a service line material inventory. To obtain a copy of the system's service line inventory, please visit City Hall at 108 North Van Buren Street in Newton

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# Sites over AL	Units	Violation	Likely Source of Contamination
Copper	07/13/2023	1.3	1.3	0.123	0	Ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems

Newton

Regulated Contaminates

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	12/31/2024	1.7	1.5 -1.8	MRDLG = 4	MRDL = 4	Ppm	N	Water additive used to control microbes
Halo acetic Acids (HAA5)	08/13/2024	6.0	5.8 – 5.8	No Goal for the Total	60	Ppb	N	By-product of drinking water disinfection
Total Trihalomethanes	08/13/2024	26.0	26.0 – 26.0	No Goal for the Total	80	Ppb	N	By-product of drinking water disinfection
Inorganic Compounds	Collection Date	Highest Level Detected	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	07/15/2024	0.78	0.78 – 0.78	0	10	Ppb	N	Erosion of natural deposits; Runoff from orchards; runoff from glass and electronics production wastes
Barium	07/15/2024	0.0485	0.0485 – 0.0485	2	2	Ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride	07/15/2024	0.37	0.37 – 0.37	4.0	4.0	Ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (measured as Nitrogen)	10/15/2024	2.0	1.35 – 1.7	10	10	Ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage, Erosion of natural deposits
Sodium	07/15/2024	15200	15200 – 15200			Ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration
Radioactive Contaminates	Collection Date	Highest Level Detected	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	01/22/2018	0.5	0.5 – 0.5	0	5	pCi/L	N	Erosion of natural deposits

Regulated Contaminants EFFINGHAM

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chloramines	2024	2.1	2 - 2.3	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2024	29	14 - 37.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	41	17.8 - 51	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2024	0.012	0.012 - 0.012	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2024	0.6	0.625 - 0.625	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2024	0.39	0.39 - 0.39	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	2024	26	26 - 26			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.

Turbidity

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.14 NTU	N	Soil runoff.
Lowest monthly % meeting limit	0.3 NTU	100%	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.